## Drainage **DOMESTIC VEHICLE CROSSING** -125 x 150 Dropped kerb Gradient 1 in 25 <u>20</u> <u>110</u> and Service Section A - A **Ducts** No private water to discharge onto the highway Max gradient to be 1 in 25 Max gradient to be 1 in 30 Minimum Standards 3 Dropped kerbs for a single crossing 7 Dropped kerbs for a paired crossing For narrow roads or where geometry dictates 4 or more kerbs will be required SD/5/146 Rev: Date: AMENDMENT DETAILS Notes 1. Rear edgings to be dropped parallel with the dropped kerbs. 2. 125mm x 150mm BN precast concrete kerbs should be installed for the full width of the private access. Checked by: Approved by: DRAFT -/-/-**Domestic Vehicle Crossing** NOT TO SCALE This is a typical detail and may require conversion to a full scheme specific drawing. (all units in millimetres) Disclaimer : SD/5/146 Before making use of this detail, any designer or third party must ensure that it satisfies all requirements of the scheme to which it is being applied. Lincolnshire County Council accept no responsibility for third party use of this Standard Detail.